



PLANNED SHUTDOWN PROCEDURE

1. Schedule an on-site meeting with the Contractor, Town Inspector, and Water Quality Supervisor. The Water Quality supervisor will provide a map of the area that will be affected by the work.
 - Work must be completed per Town of Apex Specifications and performed within a four (4) hour period.
2. Prior to setting the work date the contractor must contact commercial businesses that will be affected by the shutdown to determine possible hard ships as a result of the proposed shutdown.
3. Contractor prepare and email Shutdown Notification letter to Lindley Paynter, Jessica Sloan, Town Inspector and Water Quality Supervisor for approval.
4. Once approved by the Town notices to residents and businesses must be distributed by the contractor one week prior to the shutdown date. In the event of weather where work cannot be performed the following business day the contractor shall be responsible for distributing a second notice with the proposed shutdown date.
5. Contractor call in Locate Ticket for work within a reasonable time of the date of work.
6. Contractor is responsible for pre-mobilization, materials, and installation prior to date of work to help ensure work is completed within the four (4) shutdown period. Precautionary measures should be considered including necessary backup materials and other equipment that may be required to perform the work.
7. Contractor is responsible for scheduling an on-site inspection with the Town Infrastructure Inspector, Water Quality Supervisor, or Water and Sewer Operations Manager one day prior to the scheduled shutdown to check for job preparedness.
8. Prior to start time the Water Quality division will be responsible for closing the valves necessary for shutdown. After work is completed the Water Quality division will reopen the valves, flush the lines, and sample the water.

TOWN OF APEX CONTACTS

Dewayne Carlyle – Infrastructure
Inspections Manager
919-337-7877
Dewayne.carlyle@apexnc.org

Paul Leon - Inspector
919-337-7881
Paul.leon@apexnc.org

Bryce Bernard - Inspector
919-548-1743
Bryce.bernard@apexnc.org

Chad Dusenberry - Inspector
919-210-8633
Chad.dusenberry@apexnc.org

Robert Busby – Inspector
919-390-8030
Robert.busby@apexnc.org

Chris Hurt – Inspector
919-291-6090
Chris.hurt@apexnc.org

Lindley Paynter – Sr. Program
Support Specialist
919-249-3356
Lindley.paynter@apexnc.org

Jimmy Cornell – Water &
Sewer Operations Manager
919-249-3536
Jimmy.cornell@apexnc.org

John Osegueda- Water
Quality Supervisor
919-249-3411
John.osegueda@apexnc.org

Jessica Sloan – Sr. Program
Support Specialist
919-372-7478
Jessica.sloan@apexnc.org